

Summary of Preliminary Assessment on Structural, Fire and Electrical Safety

| | |
|------------------------------------|---|
| Name of the Factory | : Apt Garments Ltd. |
| Address of the Factory | : Palli Biddut Road, Mulaid, Sreepur, Gazipur |
| Present Status of the Factory | : Under operation. |
| Structural Assessment Conducted by | : VEC |
| Date of Structural Inspection | : 9 April, 2015 |
| Fire Assessment Conducted by | : VEC |
| Date of Fire Inspection | : 9 April, 2015 |
| Electrical Assessment Conducted by | : VEC |
| Date of Electrical Inspection | : 9 April, 2015 |
| BGMEA Membership No. | : 5566 |

BASIC INFORMATION:

The factory building is a three storied RCC building with beam and column system and flat slab system. The following information was noted:

| | |
|-------------------------------|---|
| i. Building Usage Type | : Garment Factory. |
| ii. Structural System | : Non Engineering single storey steel shed (truss-column steel frame). |
| iii. Floor System | : Roof truss. |
| iv. Floor Area | : Shed -1 is 1620 sft. Shed -2 is 1400 sft. Shed -3 is 4186 sft. |
| v. No. of Stories | : Single storied |
| vi. Construction Year | : 2013 |
| vii. Foundation Type | : Isolated footing |
| viii. Design Drawings | : Available: Approval plan, structural drawing and soil test report. Not available: Architectural drawing, machine layout plan and material test report. |
| ix. Soil Investigation Report | : Available |
| x. Construction Materials | : Brick aggregate. |
| xi. Generator | : Ground Floor. |

RECOMMENDATIONS FOR CORRECTIVE ACTION:

The recommendations of corrective action for both Structural and Fire & Electrical Safety comprises in Short Term, Mid Term and Long Term basis.

The recommendations for **Structural Safety** corrective action are:

| | |
|------------------------|---|
| Short Term (Immediate) | : N/A |
| Mid Term (6-weeks) | : 1. Design should be checked by the Building Engineer to verify the lateral stability of the shed and confirm the requirement of any bracing in the long direction |
| Long Term (6-months) | : 1. Install lateral bracing if required. 2. Prepare related structural as built document and building engineer to calculate the structural Integrity of the existing structure against wind load. |

Summary of Preliminary Assessment on Structural, Fire and Electrical Safety

The recommendations for **Fire & Electrical Safety** corrective action are:

(A): Recommendations for Fire Safety Corrective Actions:

| | |
|--|---|
| <p>Immediate</p> <p><i>(the factory should not continue to be occupied until these non-conformities have been rectified):</i></p> | <ul style="list-style-type: none"> • N/A |
| <p>Short Term</p> <p><i>(Actions that must be incorporated into a Fire Safety Management Plan immediately (1 ~ 2 weeks) and should be a regular activity</i></p> | <ul style="list-style-type: none"> • Ensure adequate numbers of fire drills under the fire safety plan. • Factory needs to have sufficient number and width (0.9 m) of marked aisles in the factory. • Factory needs to have sufficient total width of marked aisles (5 mm per occupant) of the factory. • Lights in storage area needed to be installed with protective covers and conduits. • Storage facilities with no air-conditioning duct shall be minimum 2.9 m and when used as a storage facility there shall be a minimum clearance of one-third the floor height from the ceiling to the top of the storage stack. • Ensure adequate exit signs in all floors so that it is visible from all positions |
| <p>Mid Term</p> <p><i>(The remedial works indicated must be carried out within a period of 6 weeks)</i></p> | <ul style="list-style-type: none"> • Needs to have as built drawing with floor machine layout showing means of escape with proper dimension. • Factory need to have valid fire license covering the full occupied area. • Factory needs to have proper testing plan & record for fire safety equipment. • Minimum width of door shall be at least 0.9 m & height shall be 1 m. • Provide continuous guards and handrails on both sides of the stairs. • Ensure adequate illuminated emergency lighting in floors, exits & staircases. • All the exit doors need to be replaced by side swinging so that unlockable doors can be opened easily in the direction of evacuation without the use of a key. • This is a shed. So detectors shall be installed by 900 sq-ft in one detector. • The factory with shall be equipped with manually operated electrical fire alarm system and automatic fire alarm system. |

Summary of Preliminary Assessment on Structural, Fire and Electrical Safety

| | |
|---|--|
| | <ul style="list-style-type: none"> Manually operated electrical alarm system shall be installed in a building with single or multiple call boxes located on each floor. Factory needs to install control panel for detection and alarm system at required location. |
| <p>Long Term</p> <p><i>(The remedial works indicated must be carried out within a period of 6 months)</i></p> | <ul style="list-style-type: none"> Factory needs to have a proper pre-plan for fire service & civil department. North-east exit-1 passes beside generator room and south-middle. Exit-1 passes beside generator room. Generator, substation & transformer room needs to be fire separated with 4hours fire rated enclosure and 2 hours rated opening having direct access from outside. Boiler room needs to be separated with 4 hours fire rated enclosure and 2 hours rated door/opening. Install proper standpipe system having at least 75 mm dia of standpipe. Factory needs to install 1 riser per 1000 m2 of floor area and 38 mm dia of hoses with variable nozzle. Ensure the minimum pressure for standpipes supplying a 50 mm or larger hose shall be at least 300 Kpa. For standpipe supplying first aid hose (38mm nominal) may have a minimum pressure of 200 Kpa. Factory needs to install Siamese connection after installation of stand pipe system, hose system and fire pump. Factory needs to install dedicated fire pump with sufficient capacity and backup power. Factory needs to have sufficient water storage capacity to get adequate pressure to feed fire-fighting equipment and at least 1900ltr x 75min=142500 liters water storage tank. |

(B): Recommendations for Electrical Safety Corrective Actions:

| | |
|--|--|
| <p>Immediate</p> <p><i>(the factory should not continue to be occupied until these non-conformities have been rectified):</i></p> | <ul style="list-style-type: none"> Find out the cause (improper cable/over current selection, over loading, improper lug, improper cable joints, rusted connection, insulation damage, multiple cables at single point,) of overheating (> ambient+ 40C) and take proper action |
| <p>Short Term</p> <p><i>(Actions that must be incorporated into a Fire Safety Management Plan immediately (a week) and should be a</i></p> | <ul style="list-style-type: none"> Discharge the generator exhaust to the exterior of the shed in a safe location. Provide two separate and distinct connections of earthing for each generator. |

Summary of Preliminary Assessment on Structural, Fire and Electrical Safety

| | |
|--|--|
| <p><i>regular activity</i></p> | <ul style="list-style-type: none"> • Ensure all panel boards (including panel door) are earthed properly. • Remove all unused cables from distribution boards and make sure all necessary cables are properly terminated at its point of termination using appropriate size and type of lug. • Ensure proper earthing connections at all electrical equipment. • Clean interior components from dust and debris and seal all openings within the enclosure to prevent dust and debris from entering. • Install earthing pit for the factory with adequate provision for inspection of the earthing system and ensure inspection is being completed and documented |
| <p>Mid Term <i>(The remedial works indicated must be carried out within a period of 6 weeks)</i></p> | <ul style="list-style-type: none"> • Install appropriate number and type of safety signage and fire-fighting equipment at substation and generator room. Also ensure graded rubber mats are provided in front of all panel boards. • Provide Instruction board for first aid and artificial respiration in the generator room. • Provide dedicated & adequate size of earthing with proper identification for each circuit and ensure continuous earth path is back to main shed intake. • Rewire to avoid the use of multiple cables from incoming and outgoing side of MCB's/MCCB's and busbar. • Replace wooden bases with metal clad construction for mounting the switch controls. • Provide adequate support or mechanical guards for electrical equipment and wiring where necessary. • Provide adequate and noncombustible covers on cable channel. • Ensure cable joints are made in respect of conductivity, insulation and mechanical strength • Provide emergency power connection for life safety loads temporarily within 6 weeks and find out a permanent solution within 6 months. • Connect all metal in the shed to the shed earthing system. • Ensure Lighting fixtures are supported from the structure properly. • Find out the cause (improper cable/over current selection, over loading, improper lug, improper cable joints, rusted connection, insulation damage, multiple cables at single point,) of overheating { ambient+(20C- |

Summary of Preliminary Assessment on Structural, Fire and Electrical Safety

| | |
|---|---|
| | 40C)} and take proper action. |
| <p>Long Term</p> <p><i>(The remedial works indicated must be carried out within a period of 6 months)</i></p> | <ul style="list-style-type: none"> • Develop an electrical layout diagram and an as-built single line diagram detailing key components and capacity of the electrical system. • Establish a periodical Insulation and earth Resistance Measurement Program and record the related testing data. • Inspect electrical switchgear and panel boards on an annual basis. • Ensure overhead service connections to the shed are led via adequate size and type of service masts. • Ensure the generator room has adequate fire separation from the production area. • Ensure appropriate generator is housed in a room confirming it has enough space surrounding as per NTPA, table-4. • Replace wooden base with metal enclosed body for installing distribution boards. • Ensure panel boards have no opening and all live internal components are concealed properly. • Provide dedicated & adequate size of neutral with proper identification for each circuit. • Ensure each distribution board is provided with a circuit list and means of identification is provided as per list. • Ensure surface/exposed wiring are run either horizontally or vertically with proper mechanical support and avoid wiring at an angle or hanging way with improper support. • Provide proper cable terminator/connector for stranded conductors at its point of termination. • Install separate distribution boards for lighting and power circuits. • Install lightning protection system on the building |